

TEST REPORT

No. : SHMR220700189601
 Date : Jul 19, 2022
 Page: 1 of 3



CUSTOMER NAME: NANJING FEELING RUBBER & PLASTIC PRODUCES CO.,LTD
 ADDRESS: NO.11 LANHUA ROAD, QIAOLIN INDUSTRIAL PARK, PUKOU
 DISTRICT, NANJING, P.C:211100, CHINA

Sample Name : EPDM FLOOR

Above information and sample(s) was/were submitted and confirmed by the client. SGS, however, assumes no responsibility to verify the accuracy, adequacy and completeness of the sample information provided by client.

SGS Ref. No. : SHIN2207016925CM-NJIN2206002783PS
 Date of Receipt : Jul 05, 2022
 Testing Start Date : Jul 05, 2022
 Testing End Date : Jul 19, 2022
 Test result(s) : For further details, please refer to the following page(s)
 (Unless otherwise stated the results shown in this test report refer only to the sample(s) tested)

Signed for
 SGS-CSTC Standards Technical
 Services (Shanghai) Co., Ltd.

Xia Hai
 Authorized signatory

AREA SPORT SPA
 EXCLUSIVO CHILE
 CONSTRUCTORA FRAY JORGE
 proyecto: Mejoramiento Parque Brasil.
 Comuna de La Granja.



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.
 Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755) 8397 1443, or email: CS_Doccheck@sgs.com
 8th building, No. 888 Road, 1159, Kangqiao East Road, Pudong District, Shanghai, China 201319 t (86-21) 61196300 f (86-21) 68183920 www.sgs.com.cn
 中国·上海·上海浦东康桥东路1159弄69号8号楼 邮编: 201319 t (86-21) 61196300 f (86-21) 68183920 e sgs.china@sgs.com

TEST REPORT

No. : SHMR220700189601

Date : Jul 19, 2022


Page: 2 of 3

Summary of Results:

No.	Test Item	Test Method	Result	Conclusion
1	Tensile Strength	BS 7188:1998+A2:2009	2.95 MPa	Pass
	Elongation at Break		601 %	

Note: Pass : Meet the requirements;
 Fail : Does not meet the requirements;
 / : Not Apply to the judgment.

Original Sample Photo:



TEST REPORT

No. : SHMR220700189601

Date : Jul 19, 2022

Page: 3 of 3

Test Item: Tensile Test

Sample Description: Rubber part

Test Method: BS 7188:1998+A2:2009

Test Condition:

Specimen thickness: 2.061 mm

Testing speed: 100 mm/min

Gauge length: 50 mm

Lab Environmental Condition: (23 ± 2) °C, (50 ± 5) % RH

Test Result:

Test Item	Test Result	Requirement in BS 7188:1998+A2:2009 Section 8	Conclusion
Tensile Strength	2.95 MPa	≥0.4 MPa	Pass
Elongation at Break	601 %	≥75 %	Pass

Note: Test specimens were cut from the sample.

***** End of report*****

EXCLUSIVO EN CHILE
CONSTRUCTORA FRAY JORGE.
 proyecto: Mejoramiento Parque Brasil.
 Comuna de La Granja.



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755)8307 1443, or email: CN_09occheck@sgs.com
 8th building No.88 Block 1158 Kangqiao East Road, Pudong District, Shanghai, China 201319 t (86-21) 61196300 f (86-21) 68183920 www.sgs.com.cn
 中国·上海·上海浦东康桥东路1159弄69号8号楼 邮编: 201319 t (86-21) 61196300 f (86-21) 68183920 e sgs.china@sgs.com